

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0026:302 Page 1 of 1

CATEGORY: Photoelectric Smoke Detectors

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542

DESIGN: Models 912P and 912HP photoelectric type, analog/addressable smoke detectors. Model 912HP employs an integral heat sensor to assist the smoke detector in the event of fire. It is NOT approved or intended for use as a heat detector. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke detectors for use with Models M612/912, 4B or 6B base (CSFM Listing No. 7300-1493:181) and separately listed compatible fire alarm control units.

XLF: 7272-1532:104

NOTE: Formerly 7272-1493:177

06-21-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 21, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager